

General Disclaimer

One or more of the Following Statements may affect this Document

- This document has been reproduced from the best copy furnished by the organizational source. It is being released in the interest of making available as much information as possible.
- This document may contain data, which exceeds the sheet parameters. It was furnished in this condition by the organizational source and is the best copy available.
- This document may contain tone-on-tone or color graphs, charts and/or pictures, which have been reproduced in black and white.
- This document is paginated as submitted by the original source.
- Portions of this document are not fully legible due to the historical nature of some of the material. However, it is the best reproduction available from the original submission.

5105-159

Solar Thermal Power Systems Project
Parabolic Dish Systems Development

DOE/JPL-1060-85

Distribution Category UC-62

(NASA-CR-175874) A PROGRAM FOR THE
CALCULATION OF PARABOLOIDAL-DISH SOLAR
THERMAL POWER PLANT PERFORMANCE (Jet
Propulsion Lab.) 53 p HC A04/8F A01


N85-28449

Unclas

CSCL 10A G3/44 21441

A Program for the Calculation of Paraboloidal-Dish Solar Thermal Power Plant Performance

J.M. Bowyer, Jr.



April 15, 1985

Prepared for
U.S. Department of Energy
Through an Agreement with
National Aeronautics and Space Administration
by
Jet Propulsion Laboratory
California Institute of Technology
Pasadena, California

JPL Publication 85-36



5105-159
Solar Thermal Power Systems Project
Parabolic Dish Systems Development

DOE/JPL-1060-85
Distribution Category UC-62

A Program for the Calculation of Paraboloidal-Dish Solar Thermal Power Plant Performance

J.M. Bowyer, Jr.

April 15, 1985

Prepared for
U.S. Department of Energy
Through an Agreement with
National Aeronautics and Space Administration
by
Jet Propulsion Laboratory
California Institute of Technology
Pasadena, California

JPL Publication 85-36

Prepared by the Jet Propulsion Laboratory, California Institute of Technology,
for the U.S. Department of Energy through an agreement with the National
Aeronautics and Space Administration.

The JPL Solar Thermal Power Systems Project is sponsored by the U.S.
Department of Energy and is part of the Solar Thermal Program to develop low-
cost solar thermal and electric power plants.

This report was prepared as an account of work sponsored by an agency of the
United States Government. Neither the United States Government nor any
agency thereof, nor any of their employees, makes any warranty, express or
implied, or assumes any legal liability or responsibility for the accuracy, com-
pleteness, or usefulness of any information, apparatus, product, or process
disclosed, or represents that its use would not infringe privately owned rights.

Reference herein to any specific commercial product, process, or service by trade
name, trademark, manufacturer, or otherwise, does not necessarily constitute or
imply its endorsement, recommendation, or favoring by the United States
Government or any agency thereof. The views and opinions of authors
expressed herein do not necessarily state or reflect those of the United States
Government or any agency thereof.

ABSTRACT

A program capable of calculating the design-point and quasi-steady-state annual performance of a paraboloidal-concentrator solar thermal power plant without energy storage has been written for a programmable calculator equipped with suitable printer. The power plant may be located at any site for which a histogram of annual direct normal insolation is available.

Inputs required by the program are aperture area and the design and annual efficiencies of the concentrator; the intercept factor and apparent absorptance of the receiver aperture, and the receiver heat loss; the design efficiency of the power conversion subsystem and a polynomial representation of its normalized part-load efficiency; the efficiency of the electrical generator or alternator; the efficiency of the electric power conditioning and transport subsystem; and the fractional parasitic losses for the plant. (Losses to auxiliaries associated with each individual module are to be deducted when the power conversion subsystem efficiencies are calculated.)

Outputs provided by the program are the system design efficiency, the annualized receiver efficiency, the annualized power conversion subsystem efficiency, the total annual direct normal insolation received per unit area of concentrator aperture, and the system annual efficiency.

ACKNOWLEDGMENTS

The author is pleased to acknowledge the consistent encouragement and support provided to him by Mr. Toshio Fujita during the development of the simulation program that is the subject of this report. The expert editorial assistance of Ms. Peggy L. Panda is also gratefully acknowledged. Discussions with Dr. John W. Lucas following his review of the report enabled the clarification of several explanatory paragraphs; this assistance is much appreciated.

The work described herein was conducted by the Jet Propulsion Laboratory, California Institute of Technology, for the U.S. Department of Energy through an agreement with the National Aeronautics and Space Administration (NASA Task RE-152, Amendment 327; DOE/ALO/NASA Interagency Agreement No. DE-AM04-80AL13137).

CONTENTS

I.	INTRODUCTION	1-1
II.	DESCRIPTION OF THE PROBLEM AND ITS SOLUTION	2-1
A.	INPUT VARIABLES	2-1
B.	OUTPUT VARIABLES	2-2
C.	METHOD OF SOLUTION	2-3
D.	FLOW CHART	2-12
E.	ANNOTATED PROGRAM LISTING	2-12
III.	SAMPLE PROBLEM AND SOLUTION	3-1
IV.	USER INSTRUCTIONS	4-1
V.	CONCLUDING REMARKS	5-1

APPENDIXES

A.	FLOW CHART OF THE PROGRAMMED SOLUTION	A-1
B.	TI-59 PROGRAMMABLE CALCULATOR PROGRAM SEGMENT NOS. 1 AND 2	B-1
C.	THE SAMPLE PROBLEM AND ITS SOLUTION BY TI-59 PROGRAMMABLE CALCULATOR	C-1
D.	USER INSTRUCTIONS FOR LOADING AND RUNNING THE TI-59 PROGRAMMABLE CACULATOR PROGRAM	D-1

Figures

1.	Energy Exchange and Efficiency of Paraboloidal Dish Solar Thermodynamic Power Module Subsystems	2-5
2.	Histograms of the Annual Hourly Average Direct Insolation for Four Selected Sites	2-11

Tables

1. Performance Summary Input Data Form. 1-2
2. Tabular Histogram of Direct Normal Insolation Received
at Barstow, California, in Calendar Year 1976 3-1
3. Estimated Garrett Turbine Engine Company SAGT-1A Brayton
Engine Normalized Part-Load Efficiency As a Function of
Normalized Input Thermal Power 3-2

SECTION I

INTRODUCTION

A program capable of calculating the design-point and quasi-steady-state annual performance of a paraboloidal-concentrator solar thermal power plant operating without energy storage is described in this report. The program has been written for a programmable calculator equipped with a suitable printer, viz., the Texas Instruments TI-59 with PC-100C. For computational purposes, the power plant may be located at any site for which a suitable histogram of annual direct normal insolation is available.

Inputs required by the program are the design and annual efficiencies of the concentrator; the intercept factor and apparent absorptance of the receiver aperture, and the receiver heat loss per unit area of concentrator aperture; the design efficiency of the power conversion subsystem and a polynomial representation of its normalized part-load efficiency; the efficiency of the electrical generator or alternator; the efficiency of the electric power conditioning and transport subsystem; and the fractional parasitic losses for the plant. (Losses to auxiliaries associated with each individual module are to be deducted when the power conversion subsystem efficiencies are calculated.)

Outputs provided by the program are the system design efficiency, the annualized receiver efficiency, the annualized power conversion subsystem efficiency, the total annual direct normal insolation received per unit area of concentrator aperture, and the system annual efficiency. In addition, pertinent performance data for the concentrator, receiver, and power conversion subsystems, and for the entire system are output at each of the twenty-one median values of direct normal insolation included in the histogram (0.025, 0.075, . . . , 0.975, 1.025 kW/m²).

Input parameters required for the calculation of paraboloidal-dish solar thermal power plant performance, together with supporting explanatory notes, can be entered into a form such as the one presented in Table 1. This form also provides spaces for listing all the design and annual performance data pertinent to a given configuration operating under given design and annual insolation conditions.

The input and output variables and a description of the program and corresponding equations are presented in Section II, Description of the Problem and Its Solution. A flow chart and thoroughly annotated program listing are included in Appendixes A and B, respectively.

A sample problem statement and corresponding solution are presented in Section III, Sample Problem and Solution; input data for the sample problem are included in Appendix C.

Section IV, entitled User Instructions, provides step-by-step instructions for using the program.

Section V provides the concluding remarks.

Table 1. Performance Summary Input Data Form

Technology: _____

Time Frame: _____

Design Direct Normal Insolation: _____ kW/m^2

Geographic Location: _____

Annual Direct Normal Insolation: _____ $\text{kWh/m}^2/\text{y}$

Concentrator

Design Parameters

Aperture area (m^2)
 Reflectivity
 Blocking
 Efficiency

Annual Operating Parameters

Degradation
 Shading
 Efficiency

Receiver

Design Parameters

Aperture area (m^2)
 Temperature of the thermodynamic medium at the
 receiver outlet ($^{\circ}\text{F}$)
 Intercept Factor
 Conduction loss (kW_t/m^2)
 Convection loss (kW_t/m^2)
 Reradiation loss (kW_t/m^2)
 Combined losses (kW_t/m^2)
 Efficiency

Annual Operating Parameters

Efficiency

Thermal Transport

Design Efficiency
 Annual Efficiency

Power Conversion Efficiency

Design Parameters

Heat Engine Efficiency
 Generator Efficiency
 Power Conversion System Efficiency

Annual Power Conversion

System Efficiency

Power Conditioning and Transport Efficiency

1 - (Fractional Parasitic Losses)

System Performance

Design Parameters

Receiver Output Thermal Power (kW_t)
 Electric Power Output (kW_e)
 Efficiency

Annual Performance

Efficiency

Performance	
Design Point	Annual
(a)	
	(b)
	(c)
(d)	
(e)	
(f)	
	(g)
(h)	
	(i)
	(j)

Notes are presented on the following page.

Table 1. (Cont'd): Notes on the Performance Summary Input Data Form

- (a) The power conversion assembly package and its supporting struts block insolation that would otherwise fall on the concentrator. This blocking reduces the performance of the concentrator.
- (b) Between cleanings, the design reflectivity of the concentrator mirrors is degraded by the gradual accumulation of dust on the first surface of the mirror panels but is virtually completely restored by proper cleaning.
- (c) The annual performance of the usual optimal concentrator field is degraded by the shading of some concentrators by others at times considerably removed from solar noon. This is particularly true during the winter.
- (d) The apparent absorptance for concentrated insolation of the receiver apertures considered here is assumed to differ negligibly from unity.
- (e) The maximum bulk temperature achieved by the thermodynamic medium as it moves through the complete cycle is noted here.
- (f) Thermal energy is lost from the receiver through the parallel paths of (1) reradiation through the aperture, (2) direct convection at the aperture, and (3) conduction through the body and/or supports of the receiver followed by convection from the surface of the receiver body. One minus the sum of these losses (expressed as fractions of energy entering the receiver cavity) represents the transfer factor for energy entering the receiver aperture.
- (g) Receiver annual efficiency is affected by the insolation histogram employed, even in the case of a non-storage system.
- (h) Because the receiver and thermodynamic engine subsystems are closely coupled in a point-focusing thermodynamic power module, the module's thermal transport efficiency differs negligibly from unity. Annual thermal transport efficiency is assumed equal to the design thermal transport efficiency.
- (i) Power conversion annual efficiency is affected by the insolation histogram employed, even in the case of a non-storage system.
- (j) Annual system efficiency is a function of both receiver and power conversion annual efficiencies and thus is affected by the insolation histogram employed, even in the case of a non-storage system.

SECTION II

DESCRIPTION OF THE PROBLEM AND ITS SOLUTION

A. INPUT VARIABLES (All in Segment No. 1)

<u>Algebraic Variable</u>	<u>Acronym</u>	<u>Definition</u>
I_{DND}	IDND	Design level of direct normal insolation (often assumed to be 0.8 or 1.0 kW/m ²).
η_{CD}	HCD	Design efficiency of the concentrator.
η_C	HC	Annual average efficiency of the concentrator (degraded by mirror soiling and by the mutual shading of grouped concentrators).
Q_{RL}	QRL	Receiver combined thermal loss in kW _t /m ² of concentrator area projected onto the concentrator aperture plane.
ϕ	FSBS	Intercept factor of the receiver aperture, i.e., the fraction of concentrated solar radiation falling on the aperture plane of the receiver that passes through the aperture.
α	ALPH	Apparent absorptivity of the receiver aperture for the concentrated insolation incident on it.
η_{PD}	HPD	Design efficiency of the engine.
a_n	ANPS	The degree of the polynomial representation must be no greater than 6.
	NOTE:	PPX-59 Professional Program 208008 <u>Polynomial Regression</u> by T. H. Wismuller has been most useful in evaluating the required polynomial coefficients from graphs of normalized power conversion efficiency as a function of normalized input thermal power.
η_{EGT}	HEGT	Efficiency of the combined electrical generator, and transport and power conditioning subsystems.
η_p	HPAR	Correction factor by which the gross output of the power plant must be multiplied in order to account for losses due to plant auxiliary equipment, office and control room space conditioning, etc.

<u>Algebraic Variable</u>	<u>Acronym</u>	<u>Definition</u>
I_{DN}	IDN	Actual level of direct normal insolation at which performance is to be determined (kW/m^2).
H	HRS	Annual total hours of direct normal insolation at intensity centered at I_{DN} ($\Delta I_{DN} = 0.05 \text{ kW/m}^2$).
N	NPOL	Degree of the polynomial representing the normalized power conversion subsystem efficiency. $0 \leq N \leq 6$ (Integer).

B. OUTPUT VARIABLES

1. In Segment No. 1

<u>Algebraic Variable</u>	<u>Acronym</u>	<u>Definition</u>
η_{CD}	HCD	Concentrator design efficiency (an input variable).
η_{RD}	HRD	Receiver design efficiency.
η_{PD}	HPD	Power conversion subsystem design efficiency defined as thermal input to electrical generator output (an input variable).
η_{EP}	HEP	Efficiency of electrical power conditioning and transport including an allowance for module or plant parasitic power requirements.
η_{SD}	HSD	System design efficiency.

2. In Segment No. 2

<u>Algebraic Variable</u>	<u>Acronym</u>	<u>Definition</u>
At each value of I_{DN} :		
η_C	HC	Concentrator efficiency.
η_{CN}	HCN	Normalized concentrator efficiency, HC/HCD .
Q_C	QC	Concentrator photon power output per unit concentrator area (kW/m^2).
Q_{CN}	QCN	Normalized concentrator photon power output, Q_C/Q_{CD} . (See page 2-6 for the definition of Q_{CD} .)
η_R	HR	Receiver efficiency.

<u>Algebraic Variable</u>	<u>Acronym</u>	<u>Definition</u>
η_{RN}	HRN	Normalized receiver efficiency, HR/HRD.
Q_R	QR	Receiver thermal power output per unit concentrator area (kW/m^2).
Q_{RN}	QRN	Normalized receiver thermal power output, QR/QRD.
η_P	HP	Power conversion subsystem efficiency.
η_{PN}	HPN	Normalized power conversion subsystem efficiency, HP/HPD.
Q_P	QP	Power conversion subsystem electrical power output per unit concentrator area (kW/m^2).
Q_{PN}	QPN	Normalized power conversion subsystem electrical power output, QP/QPD.
η_S	HS	System efficiency.
η_{SN}	HSN	Normalized system efficiency, HS/HSD.
Q_S	QS	System electrical power output per unit concentrator area (kW/m^2).
Q_{SN}	QSN	Normalized system electrical power output, QDS/QSD.

Annual Performance:

η_{RA}	HRA	Annual average receiver efficiency.
η_{PA}	HPA	Annual average power conversion subsystem efficiency.
ΣE_I	ΣEI	Annual direct normal insolation [$\text{kW}/(\text{m}^2\text{y})$].
η_{SA}	HSA	Annual average system efficiency.

C. METHOD OF SOLUTION

As indicated in both the abstract and the introduction, the program presented here has been developed to allow calculation of the design-point and quasi-steady-state annual performance of a modular solar thermal electric power plant, each module of which comprises (1) a sun-tracking, point-focusing concentrator and (2) a power conversion assembly that is mounted on the concentrator with the receiver aperture near the focal plane and on the optical axis of the concentrator. In turn, the power conversion assembly comprises a cavity receiver, a thermodynamic engine complete with auxiliaries, and an electrical generator. The electrical control and conditioning equipment directly associated with each modular power conversion assembly may

be concentrator-mounted or ground-mounted, or parts of it may be concentrator-mounted and the remainder, ground-mounted. Typically, the power plant in its entirety will require additional power control and conditioning equipment to enable connection to a power grid and to supply auxiliary power to the modules, at least during start-up.

It is again emphasized that the program developed here is valid only for a power plant that has negligible energy storage capacity for either thermal or electric energy.

Another more subtle but ordinarily less important limitation of the program is that the plant power output may exceed its design value if the direct normal insolation exceeds the design value selected for this parameter. More sophisticated programs ordinarily impose the requirement that the design output of the power plant never be exceeded, wasting the excess power if necessary. However, because of TI-59 limitations in available program steps and memory cells, the author has been unable to incorporate this feature into the program presented here. If the direct normal insolation received at a given site seldom exceeds the selected design value or only exceeds it by small amounts, this limitation on the program is negligible. On the other hand, if a design direct normal insolation of 800 W/m^2 were chosen for a plant whose power conversion subsystem could accept the energy collected by the concentrator at a direct normal insolation of 1000 W/m^2 and if this plant were located in the desert Southwest, the difference in annual performance as calculated by this program and by one limiting output to the design maximum would be appreciable.

Figure 1 has been included so as to provide a graphic representation of the energy path through the power plant. Most of the direct normal insolation collected, reflected, and concentrated by the concentrator is directed to the receiver as photon energy; most of the photon energy absorbed by the receiver is transferred as thermal energy to the thermodynamic engine; the thermodynamic engine converts some of the thermal energy to mechanical energy and rejects or loses the remainder; the generator converts most of the mechanical energy to electrical energy with only slight energy dissipation; the module's electrical power control and conditioning transfers the energy to the plant control and conditioning system, again with relatively small losses; finally, the plant control and conditioning system transfers most of this energy to the electrical grid, while most of the remainder is absorbed by plant auxiliaries and the rest is dissipated.

Concentrator performance is determined in the following manner. At design conditions,

$$A_C Q_{CD} = A_C I_{DND} \rho_C F_B \quad \text{in kW}$$

represents the photon flux transmitted to the receiver aperture plane by the concentrator at design conditions, where A_C represents the concentrator's reflecting surface area projected on the plane of the concentrator aperture, ρ_C represents mirror reflectance, and F_B represents the fraction of A_C that is blocked by the power conversion assembly package and its supporting




Figure 1. Energy Exchange and Efficiency of Paraboloidal-Dish Solar Thermodynamic Power Module Subsystems

struts. I_{DND} is defined in Section A of this chapter. Under general conditions,

$$A_C Q_C = A_C I_{DN} \rho_C F_B \cdot F_{DG} \cdot F_S ,$$

where F_{DG} represents the average fractional degradation of mirror reflectivity that results from dust accumulation on the first surfaces of the mirrors between cleanings, and F_S represents the average degradation of concentrator field performance for the entire power plant due to the shading of some concentrators by others. Even in an optimally distributed field of concentrators, shading is appreciable near sunrise and sunset and, at latitudes appreciably above or below the equator, is more important in the winter than in the summer. Obvious definitions can be written for the design and general efficiencies of the concentrator as

$$\eta_{CD} = \rho_C F_B$$

and

$$\eta_C = \rho_C F_B F_{DG} F_S ,$$

respectively. Then Q_{CD} and Q_C can be expressed by

$$Q_{CD} = \eta_{CD} I_{DND}$$

and

$$Q_C = \eta_C I_{DN} .$$

Note that Q_{CD} , Q_C , and all other Q 's in the following discussion represent energy flux per unit area of concentrator reflective surface projected upon the aperture plane of the concentrator. Defining the Q 's in this way allows any one of them along the path of energy transport and conversion to be compared directly with the incident direct normal radiation, I_{DN} . A normalized photon flux from the concentrator, valid for annual average conditions of shading and degradation, can then be defined for an arbitrary I_{DN} as

$$Q_{CN} = Q_C / Q_{CD} .$$

The definition of receiver efficiency employed by the program is more complicated than that for the concentrator. Receiver thermal flux delivered to the thermodynamic engine is defined in the following way:

$$Q_{RD} = \alpha\phi Q_{CD} - Q_{RL} ,$$

where all the parameters and variables on the right side of this equation have already been defined. Defining receiver design efficiency as

$$\eta_{RD} = \frac{Q_{RD}}{Q_{CD}} ;$$

by substitution,

$$\eta_{RD} = \alpha\phi - \frac{Q_{RL}}{Q_{CD}} .$$

At other than design conditions, the receiver thermal flux delivered to the engine is defined as

$$Q_R = \alpha\phi Q_C - Q_{RL} ,$$

and receiver design efficiency can be defined as

$$\begin{aligned} \eta_R &= \frac{Q_R}{Q_C} \\ &= \alpha\phi - \frac{Q_{RL}}{Q_C} . \end{aligned}$$

Then from earlier definitions,

$$\eta_{RD} - \eta_R = - \frac{Q_{RL}}{Q_{CD}} \left(1 - \frac{1}{Q_C/Q_{CD}} \right)$$

and

$$\eta_R = \eta_{RD} + \frac{Q_{RL}}{Q_{CD}} \left(1 - \frac{1}{Q_{CN}} \right) .$$

Finally, a normalized receiver efficiency can be defined as

$$\eta_{RN} = \eta_R / \eta_{RD} \quad .$$

As can be seen from the formulae for η_R , at insolation levels below a certain threshold, receiver thermal efficiency can become negative. The program presented here sets $\eta_{RN} = 0$ whenever $\eta_R < 0$ is calculated; obviously, all subsequent Q 's and η 's except η_p are set equal to zero for insolation levels below this threshold.

The evaluation of the energy flux through the remainder of the power conversion subassembly is treated in a manner different from that employed in the case of the concentrator or receiver. The full-load efficiency of the engine is considered known from extensive analysis and/or experiment by the manufacturer. The same knowledge is usually available for the generator and the complete power conditioning and transport system. The fractional parasitic losses for the plant are also known from experiment or have been estimated.

In the program presented here, parasitic losses are assumed to be a small constant fraction of the gross plant-produced, conditioned, and transported electrical output; thus, a constant component efficiency reflecting plant parasitic losses can be defined as

$$\eta_{PAR} = 1 - f_{PAR} \quad ,$$

where f_{PAR} represents the normalized fractional parasitic losses just described. The efficiencies of the generator and of the electrical power conditioning and transport subsystem can be entered during the first segment of program execution as normalized fractional constants. Typically, real generator and electrical conditioning and transport subsystems exhibit efficiencies that reflect a relatively small, constant, fractional no-load loss and an additive fractional loss that varies with the fraction load. This same behavior is also exhibited by the typical thermodynamic engine. Therefore, if the user of this program wishes a more accurate representation of the combined efficiency of the engine, generator, and power conditioning and transport subsystems and if combined efficiency as a function of load is known or can be estimated for this combination, a polynomial representation for this efficiency, $\eta_p \cdot \eta_{EGT}$, can be entered during the loading phase (Segment No. 1) of the program in place of $\eta_{PN} = \eta_{PN}\{Q_{RN}\}$, and $\eta_{EGT} = 0$ can be set. Another alternative often employed by the author is to define the normalized efficiency of the engine-generator combination by a least-squares-best-fit polynomial function of normalized thermal flux from the receiver to the engine (converted from the manufacturer's data presenting efficiency as a function of output for this combination) and to assume respective constant values for η_{EGT} and f_{PAR} , the efficiency of the power conditioning and transport subsystem, and the fractional parasitic losses, respectively.

In the sample problem and corresponding solution here, η_{EGT} and η_{PAR} have been defined as constants, and only the efficiency of the engine has been defined as a function of the heat flow into the engine.

The program presented here allows the representation of normalized engine efficiency as a polynomial function of normalized thermal flux to the engine from the receiver. This representation is limited to a polynomial of no more than sixth degree.

Once the normalized thermal flux from the receiver, Q_{RN} , has been determined, the normalized efficiency of the engine, η_{PN} , can be calculated. Then the normalized mechanical output power of the engine, its efficiency, and its dimensional mechanical output power can be calculated:

$$Q_{\text{PN}} = \eta_{\text{PN}} \cdot Q_{\text{RN}} ,$$

$$\eta_{\text{P}} = \eta_{\text{PN}} \cdot \eta_{\text{PD}} ,$$

and

$$Q_{\text{P}} = \eta_{\text{P}} \cdot Q_{\text{R}} .$$

As was the case with the receiver, at input thermal fluxes to the engine below some threshold, η_{P} will be negative. When this occurs, the program sets $\eta_{\text{PN}} = 0$, and all subsequent Q 's and η 's in the energy train are also set equal to zero.

If the product of η_{EGT} (the efficiency of the generator and electrical power conditioning and transport subsystem) and η_{PAR} (the normalized fractional correction for plant parasitic electrical power dissipation) is defined as η_{EP} , the electrical power output of the plant can be calculated for design and arbitrary loads as

$$Q_{\text{SD}} = \eta_{\text{EP}} \cdot Q_{\text{PD}}$$

and

$$Q_{\text{S}} = \eta_{\text{EP}} \cdot Q_{\text{P}} .$$

For design and arbitrary loads, plant efficiency can be obtained from the simple formulae,

$$\eta_{\text{SD}} = Q_{\text{SD}} / I_{\text{DND}}$$

and

$$\eta_{\text{S}} = Q_{\text{S}} / I_{\text{DN}} .$$

A formula for the normalized system efficiency of the plant is

$$\eta_{SN} = \eta_S / \eta_{SD} \quad .$$

The assumption of quasi-steady plant operation allows all transients due to abrupt changes in insolation to be ignored; thus, it becomes unnecessary to employ a dynamic temporal record of direct normal insolation at a particular site in order accurately to simulate annual plant performance. A histogram of annual direct normal insolation at the same site serves just as well under this assumption, and, instead of making thousands of calculations of plant performance to obtain annual plant performance, only a few tens of calculations of plant performance are required. Histograms for a few typical sites during what have been judged to be representative years are presented in Figure 2.

Annual plant performance for a plant is calculated by the program in the following way. At the average I_{DN} corresponding to each incremental ΔI_{DN} , energy fluxes are calculated and multiplied by the number of hours during the year in which that particular I_{DN} was measured:

$$E_I = I_{DN} \cdot H$$

$$E_C = Q_C \cdot H$$

$$E_R = Q_R \cdot H$$

$$E_P = Q_P \cdot H$$

$$E_S = Q_S \cdot H$$

These individual energies are then added to the sum of corresponding energies determined for all the previously employed (smaller) values of average I_{DN} . When all bands of I_{DN} have been considered, summations for the year are then available:

$$\Sigma E_I = \Sigma (I_{DN} \cdot H)$$

$$\Sigma E_C = \Sigma (Q_C \cdot H)$$

$$\Sigma E_R = \Sigma (Q_R \cdot H)$$

$$\Sigma E_P = \Sigma (Q_P \cdot H)$$

$$\Sigma E_S = \Sigma (Q_S \cdot H)$$







Figure 2. Histograms of the Annual Hourly Average Direct Insolation for Four Selected Sites

Finally, from these annual summations, the annual average efficiencies of the receiver, the engine, and the system can be calculated:

$$\eta_{RA} = \Sigma E_R / \Sigma E_C$$

$$\eta_{PA} = \Sigma E_P / \Sigma E_R$$

$$\eta_{SA} = \Sigma E_S / \Sigma E_I$$

The annual average efficiency of the concentrator was established near the beginning of this section. It is therefore unnecessary to determine

$$\eta_{CA} = \Sigma E_C / \Sigma E_I ,$$

although this equation can be employed as a check.

D. FLOW CHART

The flow chart (Appendix A) of the programmed solution follows standard flow charting conventions and is virtually self-explanatory. Segment No. 1 is stored on the first TI-59 program card and Segment No. 2, on the second. The names of the various subprograms correspond to the various TI-59 keys employed as user-defined subprogram labels in the course of program development. Although an attempt was made to choose each label in a way that would provide a hint as to the function of the corresponding subroutine, the severely limited number of names available probably prevented much success in this respect. The reader must simply remember the names of the various subprograms as the various loops of the program are traced and retraced.

E. ANNOTATED PROGRAM LISTING

While the flow chart presented in Appendix A is easily adapted to any programmable calculator or microcomputer whose capabilities equal or exceed those of the TI-59, the program listing presented in Appendix B can be directly keyed in and executed only on a TI-59. Nevertheless, since a TI-59 and attached printer are still commonly available and widely used in science and engineering, the program listing has been included in this report. To those who are familiar with the TI-59 programmable calculator and the ancillary, no-longer-extant PPX-59 user's group, the form in which the listing is presented will be completely familiar. The comments accompanying the listing closely parallel the remarks presented in the flow chart.

SECTION III

SAMPLE PROBLEM AND SOLUTION

The design and annual performances of a paraboloidal concentrator (dish)/Brayton solar thermal power plant (PDB/STPP) operating without thermal or electrical storage capability at Barstow, California, is considered here. A histogram of the direct normal insolation received at Barstow in 1976 is presented in tabular form as Table 2.

The design value for direct normal insolation is assumed to be 1.0 kW/m^2 . Design and annual values of concentrator efficiency are assumed to be 0.94 and 0.88, respectively.

A receiver outlet temperature of 870°C (1600°F) has been specified. The corresponding combined thermal loss, intercept factor, and apparent aperture absorptance for the receiver have been estimated to be 0.07445 kW/m^2 (based on concentrator aperture), 0.99, and 0.92, respectively. The design efficiency of the Brayton engine has been estimated as 0.271, and the normalized part-load characteristics of the engine are presented in Table 3.

Table 2. Tabular Histogram of Direct Normal Insolation Received at Barstow, California, in Calendar Year 1976

Insolation Increment	Hours of Insolation in this Increment
0.00 - 0.05	251
0.05 - 0.10	174
0.10 - 0.15	131
0.15 - 0.20	109
0.20 - 0.25	111
0.25 - 0.30	122
0.30 - 0.35	94
0.35 - 0.40	92
0.40 - 0.45	96
0.45 - 0.50	111
0.50 - 0.55	141
0.55 - 0.60	129
0.60 - 0.65	143
0.65 - 0.70	192
0.70 - 0.75	228
0.75 - 0.80	288
0.80 - 0.85	345
0.85 - 0.90	489
0.90 - 0.95	595
0.95 - 1.00	508
1.00 - 1.05	60

Table 3. Estimated Garrett Turbine Engine Company SAGT-1A
Brayton Engine Normalized Part-Load Efficiency
As a Function of Normalized Input Thermal Power

Normalized Input Thermal Power	Normalized Part-Load Efficiency
0.295	0.000
0.375	0.515
0.500	0.827
0.625	0.940
0.750	0.989
0.875	1.000
1.000	1.000

The coefficients of the sixth-degree polynomial approximation corresponding to this normalized part-load operating characteristic are as follows:

$$a_0 = -11.484$$

$$a_1 = +93.721$$

$$a_2 = -303.71$$

$$a_3 = +532.70$$

$$a_4 = -526.26$$

$$a_5 = +257.56$$

$$a_6 = -59.527$$

The combined efficiency of mechanical-to-electrical power conversion by the generator, the power conditioning equipment, and the electrical transport network has been estimated to be 0.95, while the correction factor to the gross output of the power plant required to account for losses due to plant auxiliary equipment, etc., has been estimated to be 0.98.

As indicated by the sample problem (Appendix C), the input segment of the program requests the entry of the input data, item by item. Entering the degree of the polynomial (NPOL) and starting the program results in (1) calculation and printing of the design performance parameters corresponding to the PDB/STPP configuration specified by the input parameters and (2) a printed directive to load the second segment of the program into the calculator.

After the second segment is loaded and started, the annual performance of the specified PDB/STPP is calculated. When the calculator stops, the calculation is complete. The following results have then been presented: (1) performance data for the concentrator, receiver, engine, and complete system for each median value of direct normal insolation employed in the histogram -- only the results obtained at $I_{DN} = 0.025$ are labeled -- and (2) the total direct normal insolation received during the year per square meter of concentrator aperture area and the annual average efficiencies of the receiver, thermodynamic engine, and the system in its entirety.

SECTION IV

USER INSTRUCTIONS

While the instructions presented in Appendix D are intended primarily for instruction of the TI-59 user and while the contents of the data registers are uniquely applicable to the TI-59, the general sequence of instructions is certainly applicable to any programmable calculator or microcomputer that might be employed to solve the problem.

SECTION V

CONCLUDING REMARKS


The results obtained for a wide variety of paraboloidal-dish solar thermal power plants operating at various sites have been compared with hour-by-hour calculations made for the same configurations at the same sites. In every case for which the site was located in the sunbelt and for which $I_{DND} = 1.00$ was specified, the results obtained by the method described herein differed negligibly from the hour-by-hour results obtained with a mainframe computer.

For the reader who has access to a TI-59 programmable calculator and attached TI PC-100C printer, loading the program and duplicating the sample problem should be a relatively simple task.



For the reader who wishes to understand the problem and its solution, the task is more difficult. However, the author recently presented the flow chart and the TI-59 program listing that are included here to members of a senior class in mechanical engineering. Within a few days these students had rewritten the program in BASIC and within ten days had duplicated the sample problem results with a Commodore 64 computer. Since that time, these same students have successfully programmed and solved the sample problem (1) on an HP-41C programmable calculator and (2), using FORTRAN, on the university's mainframe computer. Thus, the author is convinced that, by studying this report, an interested reader who is familiar with a sufficiently capable programmable calculator or computer will be able to create a program and solve the sample problem presented herein and any similar problems of interest.



APPENDIX A


FLOW CHART OF THE PROGRAMMED SOLUTION





PRECEDING PAGE BLANK NOT FILMED









APPENDIX B

TI-59 PROGRAMMABLE CALCULATOR PROGRAM
SEGMENT NOS. 1 AND 2

ORIGINAL PART 1
OF POOR QUALITY

Segment No. 1

LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS
000	03	3		055	90	LST	FSBS → DR39	110	36	36	HCD
001	04	4		056	01	1	A	111	95	=	= QCD
002	42	STD		057	03	3		112	42	STD	
003	00	00	34 → DR00	058	02	2	L	113	40	40	QCD → DR40
004	71	SBR		059	07	7		114	98	ADV	
005	99	PRT		060	03	3	P	115	04	4	
006	02	2	I	061	03	3		116	42	STD	
007	04	4	D	062	02	2	H	117	00	00	4 → DR00
008	01	1		063	03	3	Print	118	05	5	
009	06	6		064	71	SBR	ENTER ALPH	119	42	STD	
010	03	3	N	065	90	LST	ALPH → DR40	120	33	33	5 → DR33
011	01	1		066	02	2	H	121	01	1	
012	01	1	D	067	03	3		122	01	1	
013	06	6		068	03	3	P	123	42	STD	
014	71	SBR	Print	069	03	3		124	34	34	11 → DR34
015	90	LST	ENTER IDND	070	01	1	D	125	01	1	A
016	02	2	IDND → DR35	071	06	6		126	03	3	
017	03	3	H	072	00	0		127	03	3	N
018	01	1	C	073	00	0	Print	128	01	1	
019	05	5		074	71	SBR	ENTER HPD	129	03	3	P
020	01	1	D	075	90	LST	HPD → DR41	130	03	3	
021	06	6		076	02	2	H	131	03	3	S
022	00	0		077	03	3		132	06	6	
023	00	0	Print	078	01	1	E	133	69	DP	Print
024	71	SBR	ENTER HCD	079	07	7		134	02	02	ENTER ANPS
025	90	LST	HCD → DR36	080	02	2	G	135	69	DP	
026	02	2	H	081	02	2		136	05	05	
027	03	3		082	03	3	T	137	76	LBL	
028	01	1	C	083	07	7	Print	138	78	Σ+	
029	05	5		084	71	SBR	ENTER HPAR	139	01	1	DR00 + 1
030	00	0		085	90	LST	HPAR → DR42	140	44	SUM	→ DR00
031	00	0		086	02	2	H	141	00	00	
032	00	0		087	03	3		142	43	RCL	
033	00	0	Print	088	03	3	P	143	00	00	DR00
034	71	SBR	ENTER HC	089	03	3		144	75	-	-
035	90	LST	HC → DR37	090	01	1	A	145	43	RCL	
036	03	3	Q	091	03	3	R	146	33	33	DR33
037	04	4		092	03	3		147	95	=	=n (of a _n)
038	03	3	R	093	05	5	Print	148	99	PRT	Print n
039	05	5		094	69	DP	ENTER HPAR	149	91	R/S	Enter a _n
040	02	2	L	095	02	02		150	72	ST*	Store a _n
041	07	7		096	69	DP		151	00	00	Print a _n
042	00	0		097	05	05	Enter HPAR	152	99	PRT	Continue
043	00	0	Print	098	91	R/S	Print HPAR	153	43	RCL	entering
044	71	SBR	ENTER QRL	099	99	PRT		154	34	34	and storing
045	90	LST	QRL → DR38	100	49	PRD	HPAR *	155	32	XIT	a _n through
046	02	2	F	101	42	42	HEGT → DR42	156	43	RCL	n = 6.
047	01	1		102	43	RCL		157	00	00	
048	03	3	S	103	40	40	ALPH *	158	22	INV	Note: If
049	06	6		104	49	PRD	FSBS → DR39	159	77	GE	NPOL=m < 6
050	01	1	B	105	39	39		160	78	Σ+	store a _n =0
051	04	4		106	43	RCL	IDND	161	98	ADV	for n > m.
052	03	3	S	107	35	35		162	01	1	
053	06	6	Print	108	65	x	*	163	02	2	
054	71	SBR	ENTER FSBS	109	43	RCL		164	42	STD	

LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS
165	33	33	12 + DR33	220	04	.04		275	03	3	0
166	03	3		221	01	1		276	02	2	L
167	02	2		222	44	SUM	DR00 + 1	277	02	2	
168	42	STO		223	00	00	+ DR00	278	07	7	
169	34	34	32 + DR34	224	43	RCL		279	69	OP	Print
170	02	2		225	00	00		280	02	02	ENTER NPOL
171	03	3	H	226	75	-		281	69	OP	
172	03	3		227	43	RCL		282	05	05	
173	02	2	O	228	33	33		283	25	CLR	Enter NPOL
174	04	4		229	95	=	Calculate	284	91	R/S	
175	01	1	U	230	65	x	IDN	285	42	STO	NPOL + DR04
176	03	3		231	93	.		286	04	04	Print NPOL
177	05	5	R	232	00	0		287	99	PRT	
178	69	OP		233	05	5		288	98	ADV	
179	02	02		234	85	+		289	69	OP	
180	03	3		235	93	.		290	00	00	
181	06	6	S	236	00	0		291	02	2	
182	00	0		237	02	2		292	03	3	H
183	00	0		238	05	5		293	01	1	C
184	01	1		239	95	=		294	05	5	
185	03	3	A	240	69	OP	Print IDN	295	01	1	D
186	03	3		241	06	06		296	06	6	
187	07	7	T	242	69	OP		297	69	OP	
188	00	0		243	00	00		298	04	04	
189	00	0		244	06	6		299	43	RCL	
190	69	OP		245	04	4	=	300	36	36	Print
191	03	03		246	02	2	H	301	69	OP	YYXY HCD
192	02	2		247	03	3		302	06	06	
193	04	4	I	248	03	3		303	69	OP	
194	01	1		249	05	5	R	304	00	00	
195	06	6	D	250	03	3		305	06	6	=
196	03	3		251	06	6	S	306	04	4	
197	01	1	N	252	69	OP		307	02	2	H
198	00	0		253	04	04		308	03	3	
199	00	0		254	25	CLR	Enter HRS	309	03	3	R
200	00	0		255	91	R/S	Print HRS	310	05	5	
201	00	0		256	69	OP		311	01	1	D
202	69	OP	Print	257	06	06		312	06	6	
203	04	04	ENTER	258	72	ST*	Store HRS	313	69	OP	
204	69	OP	HOURS	259	00	00		314	04	04	
205	05	05	AT	260	43	RCL	Continue	315	43	RCL	ALPH*FSBS
206	76	LBL	IDN	261	34	34	storing	316	39	39	-
207	60	DEG		262	32	XIT	HRS	317	75	-	QRL
208	98	ADV		263	43	RCL	corres-	318	43	RCL	
209	69	OP		264	00	00	ponding to	319	38	38	
210	00	00		265	22	INV	IDN until	320	55	÷	
211	06	6		266	77	GE	the 21	321	43	RCL	QCD
212	04	4	=	267	60	DEG	bins have	322	40	40	= HRD
213	02	2		268	98	ADV	been filled	323	95	=	Print
214	04	4	I	269	71	SBR		324	69	OP	YYXZ = HRD
215	01	1		270	99	PRT		325	06	06	
216	06	6	D	271	03	3	N	326	42	STO	
217	03	3		272	01	1		327	43	43	HRD + DR43
218	01	1	N	273	03	3	P	328	65	x	
219	69	OP		274	03	3		329	43	RCL	

ORIGINAL LISTING
OF PROGRAM QCDV

LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS
330	40	40	HRD x QCD	385	43	RCL	HEP	440	03	3	
331	95	=	= QRD	386	42	42		441	07	7	T
332	42	STD		387	95	=	= HSD	442	01	1	E
333	44	44	QRD → DR44	388	42	STD		443	07	7	
334	69	DP		389	45	45	HSD → DR45	444	03	3	R
335	00	00		390	69	DP	Print	445	05	5	
336	02	2		391	06	06	YYYY = HSD	446	69	DP	
337	03	3	H	392	98	ADV		447	01	01	
338	03	3		393	71	SBR		448	92	RTN	
339	03	3	P	394	99	PRT		449	76	LBL	
340	01	1		395	03	3		450	90	LST	
341	06	6	D	396	06	6	S	451	69	DP	
342	69	DP		397	01	1		452	02	02	Print
343	04	04		398	07	7	E	453	69	DP	ENTER----
344	43	RCL		399	01	1		454	05	05	
345	41	41		400	05	5	C	455	01	1	
346	69	DP	Print	401	03	3		456	44	SUM	DR00 + 1
347	06	06	YYYY HPD	402	02	2	O	457	00	00	+ DR00
348	69	DP		403	69	DP		458	91	R/S	Enter-----
349	00	00		404	02	02		459	72	ST*	Store-----
350	06	6	=	405	03	3		460	00	00	
351	04	4		406	01	1	N	461	99	PRT	Print-----
352	02	2	H	407	01	1		462	98	ADV	
353	03	3		408	06	6	D	463	04	4	If
354	01	1		409	00	0		464	03	3	DR00 < 43
355	07	7	E	410	00	0		465	32	XIT	go to
356	03	3		411	01	1		466	43	RCL	Subroutine
357	03	3	P	412	05	5	C	467	00	00	PRT;
358	69	DP		413	01	1		468	22	INV	otherwise,
359	04	04		414	03	3	A	469	77	GE	continue.
360	43	RCL		415	69	DP		470	99	PRT	
361	42	42		416	03	03		471	01	1	
362	69	DP	Print	417	03	3		472	22	INV	DR00 - 1
363	06	06	YYYY = HEP	418	05	5	R	473	44	SUM	+ DR00
364	69	DP		419	01	1		474	00	00	
365	00	00		420	06	6	D	475	92	RTN	
366	06	6	=	421	00	0		476	00	0	
367	04	4		422	00	0		477	00	0	
368	02	2	H	423	00	0		478	00	0	
369	03	3		424	00	0		479	00	0	
370	03	3		425	00	0					
371	06	6	S	426	00	0					
372	01	1		427	69	DP	Print	138	78	Z+	List of
373	06	6	D	428	04	04	ENTER	207	60	DEG	Subroutines
374	69	DP		429	69	DP	SECOND	433	99	PRT	
375	04	04		430	05	05	CARD	450	90	LST	
376	43	RCL	HCD	431	91	R/S	End of				
377	36	36		432	76	LBL	Segment				
378	65	X	X	433	99	PRT	No. 1				
379	43	RCL	HRD	434	69	DP					
380	43	43		435	00	00					
381	65	X	X	436	01	1					
382	43	RCL	HPD	437	07	7	E				
383	41	41		438	03	3					
384	65	X	X	439	01	1	N				

Segment No. 2

LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS
000	01	1		055	43	RCL		110	43	RCL	QRD
001	01	1		056	46	46	IDN	111	44	44	=QRN
002	42	STD		057	65	*	*	112	95	=	
003	00	00	11 → DR00	058	43	RCL		113	99	PRT	Print QRN
004	76	LBL		059	37	37	HC	114	99	ADV	
005	69	OP		060	95	=	=QC	115	76	LBL	
006	22	INV	Clear	061	99	PRT	Print QC	116	44	SUM	
007	86	STF	Flag	062	42	STD	QC → DR47	117	42	STD	
008	00	00	0	063	47	47	QC	118	03	03	QRN → DR03
009	98	ADV		064	55	÷	÷	119	53	(
010	69	OP		065	43	RCL	QCD	120	43	RCL	NPOL
011	00	00		066	40	40	=QCN	121	04	04	
012	06	6	=	067	95	=	Print QCN	122	42	STD	NPOL → DR02
013	04	4		068	99	PRT	QCN → DR48	123	02	02	
014	02	2	I	069	42	STD		124	85	+	
015	04	4		070	48	48		125	05	5	
016	01	1	D	071	98	ADV		126	54)	
017	06	6		072	35	1/X	1/QCN	127	42	STD	NPOL + 5
018	03	3	N	073	75	-		128	01	01	→ DR01
019	01	1		074	01	1	1	129	01	1	DR02 + 1
020	69	OP		075	95	=	=	130	44	SUM	→ DR02
021	04	04		076	65	*	(1/QCN-1)	131	02	02	
022	01	1	DR00 + 1	077	43	RCL	*	132	73	RC*	DR(DR01)
023	44	SUM	→ DR00	078	38	38	QRL	133	01	01	= a ₆ → DSPR
024	00	00		079	55	÷	÷	134	76	LBL	If DR02=0
025	93	.		080	43	RCL	QCD	135	60	DEG	go to
026	00	0		081	40	40	-	136	22	INV	Subroutine
027	02	2		082	75	-		137	97	DSZ	RAD; other-
028	05	5		083	43	RCL	HRD	138	02	02	wise, con-
029	85	+		084	43	43	= - HR	139	70	RAD	tinue.
030	93	.	Calculate	085	95	=		140	69	OP	
031	00	0	IDN	086	94	+/-	HR	141	31	31	DR01 - 1
032	05	5		087	99	PRT	Print HR	142	53	(→ DR01
033	65	*		088	42	STD	HR → DR49	143	24	CE	DSPR
034	53	(089	49	49	HR	144	65	*	*
035	43	RCL		090	55	÷	÷	145	43	RCL	QRN
036	00	00		091	43	RCL	HRD	146	03	03	
037	75	-		092	43	43	=HRN	147	85	+	+
038	01	1		093	95	=		148	73	RC*	DR(DR01)
039	02	2		094	42	STD	HRN → DR51	149	01	01	
040	54)		095	51	51		150	54)	
041	95	=		096	61	GTO	Go to	151	61	GTO	Go to
042	69	OP	Print	097	48	EXC	Subroutine	152	60	DEG	Subroutine
043	06	06	X.XXX=IDN	098	76	LBL	EXC	153	76	LBL	DEG
044	98	ADV		099	49	PRD		154	70	RAD	
045	42	STD	IDN → DR46	100	43	RCL		155	42	STD	HPN → DR51
046	46	46		101	47	47	QC	156	51	51	HPN
047	43	RCL		102	65	*	*	157	65	*	*
048	37	37	Print HC	103	43	RCL	HR	158	43	RCL	HPD
049	99	PRT	HC	104	49	49		159	41	41	=HP
050	55	÷	÷	105	95	=	=QR	160	95	=	
051	43	RCL	HCD	106	99	PRT	Print QR	161	99	PRT	Print HP
052	36	36	=HCN	107	42	STD	QR → DR50	162	42	STD	HP → DR52
053	95	=	Print HCN	108	50	50	QR	163	52	52	
054	99	PRT		109	55	÷	÷	164	86	STF	Set

ORIGINAL PAGE IS
OF POOR QUALITY

LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS
165	00	00	Flag	220	43	RCL		275	57	57	$\Sigma QR * HRS$
166	61	GTD	0	221	03	03		276	55	-	\div
167	48	EXC	Go to	222	99	PRT	Print QPN	277	43	RCL	$\Sigma QC * HRS$
168	76	LBL	Subroutine	223	43	RCL		278	56	56	$= HRA$
169	59	INT	EXC	224	46	46		279	95	=	Print
170	43	RCL		225	71	SBR		280	69	OP	ZZXX = HRA
171	03	03	QRN	226	99	π	$\Sigma IDN * HRS$	281	06	06	
172	65	X	*	227	44	SUM	$= \Sigma EI$	282	98	ADV	
173	43	RCL	HPN	228	55	55	$\rightarrow DR55$	283	69	OP	
174	51	51	= QPN	229	43	RCL		284	00	00	
175	95	=		230	47	47		285	06	6	
176	42	STD	QPN \rightarrow DR03	231	71	SBR		286	04	4	=
177	03	03		232	89	π		287	02	2	H
178	43	RCL		233	44	SUM	$\Sigma QC * HRS$	288	03	3	
179	51	51	HPN	234	56	56	$\rightarrow DR56$	289	03	3	P
180	65	X	*	235	43	RCL		290	03	3	
181	43	RCL		236	50	50		291	01	1	A
182	41	41	HPD	237	71	SBR		292	03	3	
183	95	=	= HP	238	89	π		293	69	OP	
184	42	STD	HP \rightarrow DR52	239	44	SUM	$\Sigma QR * HRS$	294	04	04	$\Sigma QP * HRS$
185	52	52	HP	240	57	57	$\rightarrow DR57$	295	43	RCL	
186	65	X	X	241	43	RCL		296	58	58	\div
187	43	RCL	QR	242	52	52		297	55	-	$\Sigma QR * HRS$
188	50	50		243	71	SBR		298	43	RCL	$= HPA$
189	95	=	= QP	244	89	π	$\Sigma QP * HRS$	299	57	57	Print
190	99	PRT	Print QP	245	44	SUM	$\rightarrow DR58$	300	95	=	ZZXY = HPA
191	42	STD		246	58	58		301	69	OP	
192	52	52	QP \rightarrow DR52	247	43	RCL		302	06	06	
193	43	RCL	QPN	248	53	53		303	98	ADV	
194	03	03		249	71	SBR		304	69	OP	
195	99	PRT	Print QPN	250	89	π		305	00	00	
196	43	RCL	QP	251	44	SUM		306	06	6	=
197	52	52		252	59	59	$\Sigma QS * HRS$	307	04	4	
198	65	X	X	253	03	3	$\rightarrow DR59$	308	07	7	
199	43	RCL		254	02	2		309	07	7	
200	42	42	HEP	255	32	XIT	If	310	01	1	E
201	95	=	= QS	256	43	RCL	DR00 < 32	311	07	7	
202	98	ADV	QS \rightarrow DR53	257	00	00	go to	312	02	2	I
203	42	STD	QS	258	22	INV	Subroutine	313	04	4	
204	53	53		259	77	GE	OP;	314	69	OP	
205	55	\div	\div	260	69	OP	otherwise,	315	04	04	
206	43	RCL	IDN	261	98	ADV	continue.	316	43	RCL	
207	46	46		262	69	OP		317	55	55	Print
208	95	=	= HS	263	00	00		318	69	OP	ZZXZ = ΣEI
209	99	PRT	Print HS	264	06	6		319	06	06	
210	42	STD	HS \rightarrow DR54	265	04	4	=	320	98	ADV	
211	54	54	HS	266	02	2	H	321	69	OP	
212	55	\div	\div	267	03	3		322	00	00	
213	43	RCL		268	03	3	R	323	06	6	=
214	45	45	HSD	269	05	5		324	04	4	
215	95	=	= HSN	270	01	1	A	325	02	2	H
216	99	PRT	Print HSN	271	03	3		326	03	3	S
217	43	RCL		272	69	OP		327	03	3	
218	53	53		273	04	04		328	06	6	
219	99	PRT	Print QS	274	43	RCL		329	01	1	

LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS	LOC	CODE	KEY	COMMENTS
330	03	3	A	385	87	IFF		440	00	0	
331	69	DP		386	43	RCL	DR51	441	00	0	
332	04	04		387	51	51	+ DSPR	442	00	0	
333	43	RCL		388	99	PRT	Print DSPR	443	00	0	
334	59	59	$\Sigma QS * HRS$	389	87	IFF	If Flag 0	444	00	0	
335	55	-	\div	390	00	00	is set, go	445	00	0	
336	43	RCL	ΣEI	391	59	INT	to	446	00	0	
337	55	55		392	61	GTO	Subroutine	447	00	0	
338	95	=	=HSA	393	49	PRD	INT;	448	00	0	
339	69	DP	Print	394	76	LBL	otherwise	449	00	0	
340	06	06	ZZYX=HSA	395	39	CDS	to to PRD	450	00	0	
341	91	R/S	End of	396	69	DP		451	00	0	
342	76	LBL	Segment	397	00	00		452	00	0	
343	48	EXC	No. 2	398	02	2		453	00	0	
344	00	0	If	399	03	3	H	454	00	0	
345	32	X/T	DR51 \geq 0	400	03	3	P	455	00	0	
346	43	RCL	go to	401	03	3		456	00	0	
347	51	51	Subroutine	402	03	3	N	457	00	0	
348	77	GE	IFF; other-	403	01	1		458	00	0	
349	87	IFF	wise, con-	404	06	6	=	459	00	0	
350	87	IFF	tinue. If	405	04	4		460	00	0	
351	00	00	Flag 0 is	406	00	0	0	461	00	0	
352	39	CDS	set, go to	407	01	1		462	00	0	
353	69	DP	Subroutine	408	69	DP		463	00	0	
354	00	00	CDS; other-	409	01	01		464	00	0	
355	02	2	wise, continue	410	03	3	S	465	00	0	
356	03	3	H	411	06	6		466	00	0	
357	03	3		412	01	1	E	467	00	0	
358	05	5	R -	413	07	7		468	00	0	
359	03	3		414	03	3	T	469	00	0	
360	01	1	N	415	07	7		470	00	0	
361	06	6		416	00	0		471	00	0	
362	04	4	=	417	00	0		472	00	0	
363	00	0		418	69	DP		473	00	0	
364	01	1	0	419	02	02		474	00	0	
365	69	DP		420	69	DP	Print	475	00	0	
366	01	01		421	05	05	HPN= 0 SET	476	00	0	
367	03	3		422	00	0		477	00	0	
368	06	6	S	423	42	STD		478	00	0	
369	01	1		424	51	51	0 + DR51	479	00	0	
370	07	7	E	425	61	GTO	Go to				
371	03	3		426	59	INT	Subroutine				
372	07	7	T	427	76	LBL	INT				
373	00	0		428	89	π		005	69	DP	List of
374	00	0		429	53	(099	49	PRD	Subroutines
375	69	DP		430	24	CE	DSPR	116	44	SUM	
376	02	02	Print	431	65	X	*	135	60	DEG	
377	69	DP	HRN= 0 SET	432	73	RC*		154	70	RAD	
378	05	05		433	00	00	DR{DR00}	169	59	INT	
379	00	0		434	54)		343	48	EXC	
380	42	STD		435	92	RTN		385	87	IFF	
381	49	49	0 + DR49	436	00	0		395	39	CDS	
382	61	GTO	Go to	437	00	0		428	89	π	
383	49	PRD	Subroutine	438	00	0					
384	76	LBL	PRD	439	00	0					

APPENDIX C

THE SAMPLE PROBLEM AND ITS SOLUTION BY TI-59 PROGRAMMABLE CALCULATOR

- SEGMENT NO. 1: INPUT DATA AND COMPLETE DESIGN-POINT
OUTPUT DATA C-3
- SEGMENT NO. 2: OUTPUT DATA FOR SELECTED VALUES OF I_{DN}
AND FOR ANNUAL PERFORMANCE C-6

Sample Problem

Statement of Example

Given (1) the required input data describing a paraboloidal concentrator/Brayton solar thermal power plant operating without thermal or electric storage capability and (2) a histogram of the direct normal insolation received at Barstow, California, in 1976, determine the design and annual performances of the power plant when connected to a conventional electric utility grid.

ENTER	PRESS	OUTPUT/MODE	COMMENT
ENTER IDND 1.			
ENTER HCD 0.94			
ENTER HC 0.88			
ENTER QRL 0.07445			
ENTER FSBS 0.99			
ENTER ALPH 0.92			
ENTER HPD 0.271			
ENTER HEGT 0.95			

ENTER	PRESS	OUTPUT/MODE	COMMENT
ENTER HPAR			
0.98			
ENTER ANPS			
0.			
-11.484			a0
1.			
93.721			a1
2.			
-303.71			a2
3.			
532.7			a3
4.			
-526.26			a4
5.			
275.56			a5
6.			
-59.527			a6
ENTER HOURS AT IDN			
0.025	=IDN		
251.	=HRS		
0.075	=IDN		
174.	=HRS		
0.125	=IDN		
131.	=HRS		
0.175	=IDN		
109.	=HRS		
0.225	=IDN		
111.	=HRS		
0.275	=IDN		
122.	=HRS		
0.325	=IDN		
94.	=HRS		
0.375	=IDN		
92.	=HRS		
0.425	=IDN		
96.	=HRS		

ENTER	PRESS	OUTPUT/MODE	COMMENT
	0.475 111.	=IDN =HRS	
	0.525 141.	=IDN =HRS	
	0.575 129.	=IDN =HRS	
	0.625 143.	=IDN =HRS	
	0.675 193.	=IDN =HRS	
	0.725 228.	=IDN =HRS	
	0.775 238.	=IDN =HRS	
	0.825 345.	=IDN =HRS	
	0.875 489.	=IDN =HRS	
	0.925 595.	=IDN =HRS	
	0.975 508.	=IDN =HRS	
	1.025 60.	=IDN =HRS	
ENTER NPOL	6.		
		0.94 HCD .8315978723 =HRD 0.271 HPD 0.931 =HEP .1972241963 =HSD	
		ENTER SECOND CARD	

ENTER	PRESS	OUTPUT/MODE	COMMENT
		0.025 =IDN	.000 < IDN ≤ .005
		0.88	HC
		.9361702128	HCN
		0.022	QC
		.0234042553	QCN
		-2.473290909	HR
		HRN=0 SET	HRN
		0.	QR
		0.	QRN
		-3.112164	HP
		HPN=0 SET	HPN
		0.	QP
		0.	QPN
		0.	HS
		0.	HSN
		0.	QS
		0.	QSN
		0.075 =IDN	.005 < IDN ≤ .100
		0.88	Note: Output parameters at each IDN appear in the same order as that shown above for IDN = 0.025
		.9361702128	
		0.066	
		0.070212766	
		-0.217230303	Note: Because HEP = HEPD = a constant, QSN = QPN always.
		HRN=0 SET	
		0.	
		0.	
		-3.112164	
		HPN=0 SET	
		0.	
		0.	
		0.	
		0.	

ENTER	PRESS	OUTPUT/MODE	COMMENT
		0.125 =IDN	.100 < IDN ≤ .150
		0.88 .9361702128 0.11 .1170212766 .2339818182 .2813641376 0.025738 .0329255906 -2.360145651 HPN=0 SET 0. 0. 0. 0. 0. 0.	Note: This is the smallest tabulated value of IDN for which thermal output power from the receiver is positive and, therefore, for which HRN > 0.
		0.425 =IDN	.400 < IDN ≤ .450
		0.88 .9361702128 0.374 .3978723404 .7117358289 .8558653798 0.2661892 .3405251618 .0921677418 .3401023681 .0245340574 .1158134139 .0537440176 .2725021504 .0228412075 .1158134139	Note: This is the smallest tabulated value of IDN for which net power is produced by the power conversion subsystem and, therefore, for which HPN > 0.

ENTER	PRESS	OUTPUT/MODE	COMMENT
		1.025 =IDN	1.000 < IDN ≤ 1.050
		0.88	
		.9361702128	
		0.902	
		.9595744681	
		.8282611973	
		0.995987634	
		0.7470916	
		.9557243041	
		.2708914533	
		.9995994587	
		.2023807293	
		.9553414971	
		.1838209356	
		0.932040485	
		0.188416459	
		.9553414971	
		.7862375972 =HRA	
		.2489081067 =HPR	
		2847.9 =SEI	
		0.160333843 =HSA	
ORIGINAL PAGE IS OF POOR QUALITY.			

APPENDIX D

USER INSTRUCTIONS FOR LOADING AND RUNNING THE TI-59 PROGRAMMABLE CALCULATOR PROGRAM

Program Title Paraboloidal Concentrator STPP
Performance (Seg. #1)
NOTE: To start, press RST; then press

R/S					
-----	--	--	--	--	--

Partition (OP 17) Parentheses Levels
479.59 t Register ☒

Angular Mode SBR Levels Absolute Addresses ☐
(if applicable)

Library Module ID 1 Disturbs Pending Operations ☐

User Instructions

FLAGS	0	1	2	3	4	5	6	7	8	9
-------	---	---	---	---	---	---	---	---	---	---

STEP	PROCEDURE	ENTER	PRESS	OUTPUT/MODE
1	Start program segment no. 1		RST	
2	Enter IDND	XXXX	R/S	ENTER IDND
3	Enter HCD	XXXY	R/S	ENTER HCD
4	Enter HC	XXXZ	R/S	ENTER HC
5	Enter QRL	XXYX	R/S	ENTER QRL
6	Enter FSBS	XXYY	R/S	ENTER FSBS
7	Enter ALPH	XXYZ	R/S	ENTER ALPH
8	Enter HPD	XXZX	R/S	ENTER HPD
				ENTER ANPS
				0.

DATA REGISTERS (w/256)	Ind. Address Reg.
1	Polynomial pointer counter
2	" " " "
3	" " " "
4	" " " "
5	" " " "
6	" " " "
7	" " " "
8	" " " "
9	" " " "
10	" " " "
11	" " " "
12	Hours QIDN = .025
13	" " " " = .075
14	" " " " = .125
15	" " " " = .175
16	" " " " = .225
17	" " " " = .275
18	" " " " = .325
19	" " " " = .375
20	" " " " = .425
21	" " " " = .475
22	" " " " = .525
23	" " " " = .575
24	" " " " = .625
25	" " " " = .675
26	" " " " = .725
27	" " " " = .775
28	" " " " = .825
29	" " " " = .875

Continued on
page D-4

STEP	PROCEDURE	ENTER	PRESS	OUTPUT/MODE
9	Enter a0	XXZY	R/S	XXZY
				1.
10	Enter a1	XXZZ	R/S	XXZZ
				2.
11	Enter a2	XYXX	R/S	XYXX
				3.
12	Enter a3	XYXY	R/S	XYXY
				4.
13	Enter a4	XYXZ	R/S	XYXZ
				5.
14	Enter a5	XYXX	R/S	XYXX
				6.
15	Enter a6	XYYY	R/S	XYYY
				ENTER HEGT
16	Enter HEGT	XYYZ	R/S	XYYZ
				ENTER HPAR
17	Enter HPAR	XYZX	R/S	XYZX
				ENTER HOURS AT IDN
				0.025 = IDN
18	Enter hours at IDN = 0.025	XYZY	R/S	XYZY = HRS
				0.075 = IDN
19		XYZZ	R/S	XYZZ = HRS
				0.125 = IDN
20		XZXX	R/S	XZXX = HRS
:	Note: This process of entering	:		:
:	hours continues at each 0.05	:		:
:	increment of IDN to IDN = 1.025	:		:

STEP	PROCEDURE	ENTER	PRESS	OUTPUT/MODE
0		:		:
1		:		1.025 = IDN
2		YXX	R/S	YXX = HRS
3				ENTER NPOL
4		P	R/S	P
5				YXY HCD
6				YXZ = HRD
7				YXX HPD
8				YXY = HEP
9				YYZ = HSD
0				ENTER SECOND CARD
1				
2				
3				
4				
5				
6				
7				
8				
9				
0				
1				
2				
3				
4				
5				
6				
7				
8				
9				
0				
1				
2				
3				
4				

DATA REGISTERS
0
1
2
3
4
5
6
7
8
9
0
1
2
3
4
5
6
7
8
9
0
1
2
3
4

User Instructions

Program Title		Paraboloidal Concentrator STPP	
NOTE: To start, press RST; then press			
R/S			
Partition (CP 17) Parentheses Levels			
479 59	t Register	<input checked="" type="checkbox"/>	
Angular Mode (if applicable)	SBR Levels	Absolute Addresses	<input type="checkbox"/>
Library Module ID	Disturbs Pending Operations	<input type="checkbox"/>	
1			

USER DEFINED KEYS	
None	
Note: See OP 08 list following the Segment No. 2 program listing for labels employed in this segment.	

FLAGS	0	1	2	3	4	5	6	7	8	9
-------	---	---	---	---	---	---	---	---	---	---

STEP	PROCEDURE	ENTER	PRESS	OUTPUT/MODE
40	Enter program segment no. 2		RST	
			R/S	
	Note: Many data are output by this second segment of the program.			
	Refer to the output from the example problem for further details.			

DATA REGISTERS (0-9)	
0	Data registers 00 through 45 have been loaded by program segment no. 1 when segment no. 2 is started
46	IDN
47	QC
48	QCN
49	HR
50	QR
51	HRN/154/HPN
52	HP/191/QP
53	QS
54	HS
55	Σ (IDN*HRS)
56	Σ (QC*HRS)
57	Σ (QR*HRS)
58	Σ (QP*HRS)
59	Σ (QD*HRS)
0	
1	
2	
3	117/QRN/176/QPN
4	Note: QRN is stored in 03 at step 117
5	seg. no. 2 QPN
6	is stored in 03 at step 177 of seg. no. 2
7	
8	
9	

1. Report No. 85-36		2. Government Accession No.		3. Recipient's Catalog No.	
4. Title and Subtitle A Program for the Calculation of Paraboloidal-Dish Solar Thermal Power Plant Performance				5. Report Date April 15, 1985	
				6. Performing Organization Code	
7. Author(s) J. M. Bowyer, Jr.				8. Performing Organization Report No.	
9. Performing Organization Name and Address JET PROPULSION LABORATORY California Institute of Technology 4800 Oak Grove Drive Pasadena, California 91109				10. Work Unit No.	
				11. Contract or Grant No. NAS7-918	
				13. Type of Report and Period Covered JPL Publication	
12. Sponsoring Agency Name and Address NATIONAL AERONAUTICS AND SPACE ADMINISTRATION Washington, D.C. 20546				14. Sponsoring Agency Code	
15. Supplementary Notes Sponsored by the U.S. Department of Energy through Interagency Agreement DE-AI01-76ET20356 with NASA; also identified as DOE/JPL-1060-85 and as JPL Project No. 5105-159 (RTOP or Customer Code 776-81-62-03).					
16. Abstract <p>A program capable of calculating the design-point and quasi-steady-state annual performance of a paraboloidal-concentrator solar thermal power plant without energy storage has been written for a programmable calculator equipped with suitable printer. The power plant may be located at any site for which a histogram of annual direct normal insolation is available.</p> <p>Inputs required by the program are aperture area and the design and annual efficiencies of the concentrator; the intercept factor and apparent efficiency of the power conversion subsystem and a polynomial representation of its normalized part-load efficiency; the efficiency of the electrical generator or alternator; the efficiency of the electric power conditioning and transport subsystem; and the fractional parasitic losses for the plant. (Losses to auxiliaries associated with each individual module are to be deducted when the power conversion subsystem efficiencies are calculated.)</p> <p>Outputs provided by the program are the system design efficiency, the annualized receiver efficiency, the annualized power conversion subsystem efficiency, the total annual direct normal insolation received per unit area of concentrator aperture, and the system annual efficiency.</p>					
17. Key Words (Selected by Author(s)) Conversion techniques Computer programming and software				18. Distribution Statement Unclassified-Unlimited	
19. Security Classif. (of this report) Unclassified		20. Security Classif. (of this page) Unclassified		21. No. of Pages 60	
22. Price					